

**ideal**  
HEATING

# Logic Air.

Power charts  
and COP



# Logic Air 4kW power charts.

DFT = DESIGN FLOW TEMPERATURE →  
ODT = OUTDOOR DESIGN TEMPERATURE ↓

	30°C			35°C			40°C				45°C			50°C			55°C		
	Power in (kW)	Power out (kW)	COP	Power in (kW)	Power out (kW)	COP	Power in (kW)	Power out (kW)	COP		Power in (kW)	Power out (kW)	COP	Power in (kW)	Power out (kW)	COP	Power in (kW)	Power out (kW)	COP
<b>7°C</b>	0.72	4	5.59	0.77	4	5.21	0.86	4	4.64		1.02	4	3.93	1.18	4	3.4	1.33	4	3
<b>6°C</b>	0.82	4.17	5.11	0.91	4.16	4.59	1.02	4.15	4.06		1.18	4.13	3.51	1.33	4.12	3.09	1.49	4.11	2.76
<b>5°C</b>	0.9	4.32	4.82	1.01	4.29	4.24	1.14	4.27	3.73		1.3	4.25	3.27	1.45	4.22	2.91	1.61	4.2	2.61
<b>4°C</b>	0.95	4.44	4.66	1.09	4.4	4.04	1.23	4.37	3.55		1.39	4.34	3.13	1.54	4.3	2.8	1.69	4.27	2.52
<b>3°C</b>	0.99	4.53	4.59	1.13	4.49	3.96	1.28	4.45	3.46		1.44	4.41	3.07	1.59	4.37	2.75	1.74	4.33	2.48
<b>2°C</b>	1	4.65	4.66	1.15	4.6	4	1.3	4.55	3.49		1.46	4.5	3.09	1.61	4.45	2.77	1.76	4.4	2.5
<b>1°C</b>	1	4.61	4.61	1.15	4.54	3.95	1.3	4.49	3.45		1.46	4.44	3.05	1.61	4.39	2.73	1.76	4.32	2.45
<b>0°C</b>	1.01	4.56	4.54	1.16	4.49	3.88	1.31	4.44	3.39		1.46	4.38	3	1.61	4.33	2.68	1.76	4.24	2.41
<b>-1°C</b>	1.02	4.52	4.45	1.16	4.43	3.81	1.32	4.38	3.33		1.47	4.33	2.94	1.62	4.27	2.64	1.77	4.17	2.36
<b>-2°C</b>	1.03	4.48	4.34	1.18	4.38	3.73	1.33	4.32	3.26		1.48	4.27	2.88	1.63	4.22	2.58	1.78	4.09	2.3
<b>-3°C</b>	1.05	4.44	4.22	1.19	4.32	3.63	1.34	4.27	3.18		1.49	4.21	2.82	1.65	4.16	2.52	1.78	4.01	2.25
<b>-4°C</b>	1.07	4.39	4.09	1.21	4.27	3.54	1.36	4.21	3.1		1.51	4.15	2.75	1.66	4.1	2.46	1.8	3.93	2.19
<b>-5°C</b>	1.1	4.35	3.95	1.23	4.21	3.43	1.38	4.15	3.01		1.53	4.09	2.67	1.69	4.04	2.4	1.81	3.86	2.13
<b>-6°C</b>	1.13	4.31	3.8	1.25	4.16	3.32	1.4	4.1	2.92		1.56	4.04	2.59	1.71	3.98	2.33	1.82	3.78	2.07
<b>-7°C</b>	1.17	4.27	3.65	1.28	4.1	3.21	1.43	4.04	2.82		1.58	3.98	2.51	1.74	3.92	2.26	1.84	3.7	2.01

# Logic Air 5kW power charts.

DFT = DESIGN FLOW TEMPERATURE →  
ODT = OUTDOOR DESIGN TEMPERATURE ↓

	30°C			35°C			40°C				45°C			50°C			55°C		
	Power in (kW)	Power out (kW)	COP	Power in (kW)	Power out (kW)	COP	Power in (kW)	Power out (kW)	COP		Power in (kW)	Power out (kW)	COP	Power in (kW)	Power out (kW)	COP	Power in (kW)	Power out (kW)	COP
<b>7°C</b>	0.9	5	5.53	0.99	5	5.06	1.11	5	4.51		1.29	5	3.88	1.47	5	3.41	1.64	5	3.04
<b>6°C</b>	1.1	5.31	4.84	1.21	5.29	4.36	1.35	5.27	3.9		1.53	5.25	3.43	1.71	5.23	3.06	1.88	5.21	2.77
<b>5°C</b>	1.25	5.58	4.47	1.39	5.54	3.99	1.54	5.5	3.56		1.72	5.47	3.18	1.9	5.43	2.86	2.07	5.39	2.6
<b>4°C</b>	1.35	5.79	4.28	1.51	5.74	3.79	1.68	5.69	3.39		1.85	5.64	3.04	2.03	5.59	2.75	2.2	5.54	2.51
<b>3°C</b>	1.42	5.96	4.2	1.59	5.9	3.71	1.76	5.84	3.31		1.94	5.78	2.98	2.11	5.71	2.71	2.28	5.65	2.47
<b>2°C</b>	1.44	6.17	4.29	1.61	6.1	3.78	1.79	6.02	3.37		1.96	5.95	3.03	2.14	5.88	2.75	2.31	5.8	2.51
<b>1°C</b>	1.44	6.06	4.21	1.61	5.99	3.71	1.79	5.91	3.31		1.96	5.84	2.98	2.14	5.77	2.7	2.31	5.69	2.46
<b>0°C</b>	1.44	5.95	4.13	1.61	5.88	3.64	1.79	5.8	3.25		1.96	5.73	2.92	2.13	5.66	2.65	2.31	5.58	2.42
<b>-1°C</b>	1.44	5.83	4.04	1.62	5.77	3.57	1.79	5.69	3.18		1.96	5.62	2.86	2.13	5.55	2.6	2.3	5.47	2.37
<b>-2°C</b>	1.44	5.72	3.96	1.62	5.66	3.5	1.79	5.58	3.12		1.96	5.5	2.81	2.13	5.45	2.56	2.3	5.36	2.33
<b>-3°C</b>	1.45	5.6	3.87	1.62	5.54	3.43	1.79	5.47	3.06		1.96	5.39	2.76	2.13	5.34	2.51	2.29	5.24	2.29
<b>-4°C</b>	1.45	5.49	3.78	1.62	5.43	3.35	1.79	5.36	3		1.96	5.28	2.7	2.12	5.23	2.47	2.29	5.13	2.25
<b>-5°C</b>	1.46	5.37	3.69	1.62	5.32	3.28	1.79	5.25	2.93		1.95	5.17	2.65	2.12	5.13	2.42	2.28	5.02	2.21
<b>-6°C</b>	1.46	5.26	3.6	1.63	5.21	3.2	1.79	5.13	2.87		1.95	5.06	2.59	2.11	5.02	2.38	2.27	4.91	2.17
<b>-7°C</b>	1.47	5.14	3.51	1.63	5.1	3.13	1.79	5.02	2.81		1.95	4.95	2.54	2.1	4.91	2.33	2.25	4.8	2.13

# Logic Air 8kW power charts.

DFT = DESIGN FLOW TEMPERATURE →  
ODT = OUTDOOR DESIGN TEMPERATURE ↓

	30°C			35°C			40°C				45°C			50°C			55°C		
	Power in (kW)	Power out (kW)	COP	Power in (kW)	Power out (kW)	COP	Power in (kW)	Power out (kW)	COP		Power in (kW)	Power out (kW)	COP	Power in (kW)	Power out (kW)	COP	Power in (kW)	Power out (kW)	COP
<b>7°C</b>	1.44	8	5.54	1.57	8	5.1	1.76	8	4.54		2.05	8	3.91	2.34	8	3.43	2.62	8	3.05
<b>6°C</b>	1.67	8.07	4.84	1.87	8.05	4.3	2.12	8.04	3.79		2.43	8.03	3.3	2.74	8.01	2.92	3.05	8	2.62
<b>5°C</b>	1.84	8.12	4.42	2.11	8.1	3.84	2.4	8.07	3.36		2.73	8.05	2.95	3.06	8.03	2.63	3.38	8	2.37
<b>4°C</b>	1.96	8.17	4.16	2.28	8.14	3.57	2.6	8.1	3.11		2.94	8.07	2.74	3.28	8.03	2.45	3.62	8	2.21
<b>3°C</b>	2.04	8.2	4.03	2.38	8.16	3.43	2.72	8.12	2.98		3.07	8.08	2.63	3.42	8.04	2.35	3.76	8	2.13
<b>2°C</b>	2.06	8.25	4	2.41	8.2	3.4	2.76	8.15	2.95		3.11	8.1	2.6	3.46	8.05	2.33	3.81	8	2.1
<b>1°C</b>	2.07	8.25	3.99	2.41	8.2	3.4	2.76	8.14	2.95		3.11	8.08	2.6	3.46	8.04	2.32	3.81	7.94	2.09
<b>0°C</b>	2.07	8.25	3.98	2.42	8.2	3.39	2.76	8.13	2.94		3.11	8.06	2.59	3.46	8.03	2.32	3.79	7.89	2.08
<b>-1°C</b>	2.09	8.25	3.95	2.43	8.19	3.37	2.77	8.12	2.93		3.11	8.04	2.59	3.45	8.03	2.33	3.78	7.83	2.07
<b>-2°C</b>	2.11	8.25	3.9	2.44	8.19	3.35	2.78	8.11	2.92		3.11	8.03	2.58	3.45	8.02	2.33	3.75	7.78	2.07
<b>-3°C</b>	2.14	8.25	3.85	2.46	8.19	3.33	2.78	8.1	2.91		3.11	8.01	2.57	3.44	8.01	2.33	3.72	7.72	2.08
<b>-4°C</b>	2.18	8.25	3.79	2.48	8.19	3.3	2.8	8.09	2.89		3.11	7.99	2.57	3.43	8	2.34	3.67	7.67	2.09
<b>-5°C</b>	2.22	8.25	3.72	2.5	8.18	3.27	2.81	8.08	2.88		3.11	7.97	2.56	3.41	8	2.34	3.63	7.61	2.1
<b>-6°C</b>	2.26	8.25	3.64	2.53	8.18	3.23	2.82	8.07	2.86		3.11	7.95	2.56	3.4	7.99	2.35	3.57	7.56	2.12
<b>-7°C</b>	2.32	8.24	3.56	2.56	8.18	3.19	2.84	8.06	2.84		3.11	7.93	2.55	3.38	7.98	2.36	3.5	7.5	2.14

# Logic Air 10kW power charts.

DFT = DESIGN FLOW TEMPERATURE →  
ODT = OUTDOOR DESIGN TEMPERATURE ↓

	30°C			35°C			40°C				45°C			50°C			55°C		
	Power in (kW)	Power out (kW)	COP	Power in (kW)	Power out (kW)	COP	Power in (kW)	Power out (kW)	COP		Power in (kW)	Power out (kW)	COP	Power in (kW)	Power out (kW)	COP	Power in (kW)	Power out (kW)	COP
<b>7°C</b>	1.84	10	5.42	2.07	10	4.83	2.34	10	4.27		2.68	10	3.73	3.02	10	3.32	3.36	10	2.98
<b>6°C</b>	2.14	10.13	4.72	2.4	10.05	4.18	2.69	9.97	3.7		3.03	9.9	3.27	3.36	9.82	2.92	3.69	9.74	2.64
<b>5°C</b>	2.38	10.25	4.31	2.67	10.1	3.79	2.97	9.95	3.35		3.3	9.81	2.98	3.62	9.66	2.67	3.95	9.51	2.41
<b>4°C</b>	2.55	10.34	4.06	2.85	10.14	3.55	3.16	9.93	3.14		3.49	9.73	2.79	3.81	9.53	2.5	4.14	9.33	2.25
<b>3°C</b>	2.65	10.41	3.93	2.96	10.16	3.43	3.28	9.92	3.02		3.6	9.67	2.68	3.93	9.43	2.4	4.25	9.18	2.16
<b>2°C</b>	2.68	10.5	3.92	3	10.2	3.4	3.32	9.9	2.98		3.64	9.6	2.64	3.96	9.3	2.35	4.29	9	2.1
<b>1°C</b>	2.68	10.39	3.88	3	10.13	3.37	3.32	9.84	2.96		3.64	9.56	2.62	3.96	9.27	2.34	4.28	8.94	2.09
<b>0°C</b>	2.68	10.28	3.83	3	10.05	3.35	3.32	9.79	2.95		3.64	9.52	2.62	3.96	9.25	2.34	4.27	8.89	2.08
<b>-1°C</b>	2.69	10.16	3.78	3.01	9.98	3.32	3.32	9.73	2.93		3.64	9.48	2.61	3.95	9.22	2.33	4.25	8.83	2.08
<b>-2°C</b>	2.69	10.05	3.73	3.01	9.9	3.29	3.32	9.67	2.91		3.63	9.44	2.6	3.94	9.2	2.33	4.22	8.78	2.08
<b>-3°C</b>	2.7	9.94	3.68	3.02	9.83	3.26	3.32	9.62	2.89		3.63	9.4	2.59	3.93	9.17	2.33	4.19	8.72	2.08
<b>-4°C</b>	2.71	9.83	3.63	3.02	9.75	3.23	3.32	9.56	2.88		3.62	9.36	2.59	3.92	9.15	2.34	4.15	8.67	2.09
<b>-5°C</b>	2.72	9.71	3.57	3.03	9.68	3.19	3.32	9.5	2.86		3.61	9.32	2.58	3.9	9.12	2.34	4.1	8.61	2.1
<b>-6°C</b>	2.73	9.6	3.52	3.04	9.6	3.16	3.32	9.44	2.84		3.6	9.28	2.58	3.88	9.1	2.34	4.04	8.56	2.12
<b>-7°C</b>	2.74	9.49	3.46	3.05	9.53	3.12	3.32	9.39	2.83		3.59	9.24	2.58	3.86	9.07	2.35	3.97	8.5	2.14



Customer Service:

**01482 498660**

Technical Help:

**01482 498663**

Ideal Heating, PO Box 103, National Avenue,  
Kingston upon Hull, East Yorkshire, HU5 4JN

E: [enquiries@idealheating.com](mailto:enquiries@idealheating.com)

[idealheating.com](http://idealheating.com) |     